

OAA Part 3, Public Pool Supplemental Checklist

Drawings Reviewed: (titles plus dates)	Project Name: Project Number: Review By: Date: Approved By: BCDN:
---	--

Legend: **N**: Not required **R**: Required **C**: Confirm requirements or Construction detail(s) **RC**: Review completed and item indicated on documents

This checklist is intended to assist architects in a review of code requirements to be considered in the preparation and review of documents to support a permit application. A simple review of the checklist is not a substitute for a thorough review of the OBC. Modify the checklist to note applicable code requirements for the project.

			OBC Reference(s)
	a	Class (A, B, indoor, outdoor)	3.11.2.1
	b	Occupant load (d/2.5 + S/1.4)	3.11.16.3.(1) & (2)
	c	Exemptions for club, camp or institutions	3.11.3.1.(2) & (3)
	d	Elevated pool decks	3.11.3.1.(11)

2. GENERAL REQUIREMENTS

	a	Attach general notes and advise Health Department / copy of M.O.H letter to contractor	
	b	Minimum water depth $\geq 0.75\text{m}$	3.11.3.1.(4) & (5)
	c	Bottom slopes	3.11.3.1.(6)
	d	Walls vertical to within 150mm of bottom if water depth $\leq 1.35\text{m}$	3.11.3.1.(8)
	e	Ledges	3.11.3.1.(10)
	f	Pool deck	3.11.3.1.(9) (12) to (14)
	f	Pool deck width (exemption)	3.11.3.1.(2)
	h	Recessed fittings for safety buoy line at 300mm where slopes exceeds 8%	3.11.3.1.(7)
	i	Mark deck in 100mm lettering indicating depth at deep, shallow and break between gentle and deep bottom slope points: in appropriate locations indicate in words "SHALLOW AREA" "DEEP AREA" for depth 2.5m	3.11.3.1.(24)
	j	Light colour pool surfaces	3.11.3.1.(20)
	k	Notice / sign with 150mm lettering for 2.5m water depth or less to read; "CAUTION – AVOID DEEP DIVES" or "SHALLOW WATER – NO DIVING"	3.11.3.1.(25)
	l	Black disc 150mm diameter at deepest point	3.11.3.1.(21)

OAA Part 3, Public Pool Supplemental Checklist

	m	Diving boards	3.11.4.1
	n	Corresponding water depth in front of diving board	3.11.4.1.(6) to (8)
	o	Clearance above board	3.11.4.1.(15)
	p	Ladders or steps from pool	3.11.3.1.(18)

3. DRESSING, LOCKERS, SHOWERS AND TOILETS

	a	Exemption for class A&B pool alternative facilities	3.11.9.1.(2) & (3)
	b	Water closet, urinals, lavatories provided	3.7.1.2 & 3.11.9.1.(4)
	c	Showers (1 per 40 bathers)	3.11.9.1.(5)
	d	Showers for disabled	3.8
	e	Showers beside pool deck	3.11.9.1.(6)
	f	Privacy provisions (dressing area, showers, etc.)	3.11.9.1.(12) & (13)
	g	Floor sloped in washroom, showers, passages	3.11.9.1.(9)
	h	Lockable access to deck	3.11.3.1.(1B)

4. SERVICE ROOMS AND STORAGE

	a	If room contains compressed chlorine gas provide gas tight 1 hr. fire separation at or above ground with outside exit door	3.11.11.1.(2)(a)
	b	Chemical storage facility (refer to mechanical section for ventilation, hose bib and floor drain)	3.11.11.1.(2)(a)

5. EMERGENCY PROVISIONS

	a	Emergency illumination (pool and rooms)	3.11.10.1.(4) to (6)
	b	Emergency telephone	3.11.10.1.(7) & (8)
	c	Emergency stop button	3.11.10.1.(12) to (14)

6. SPECIAL POOLS (carry out detailed Code review and inspection on the following:)

	a	Public pool in the B2 and B3 occupancy ramped	3.11.5.1
	b	Modified pool	3.11.6
	c	Wave action pool	3.11.7